


Idaho Power Oregon Distribution System Planning



DSP – Public Meeting #3
May 18th, 2022

Welcome!



Thank you

for attending Idaho Power Company's
Distribution System Planning (DSP) Process

Workshop #3

DSP Workshop Goals



- Provide information to enable participation
- Start the conversation
- Gather community input on advancing a more holistic distribution system
- For the June 6th meeting, we are looking for input on projects that we will review at the end of this presentation

Agenda



- About Idaho Power
- Power Grid 101
- Distribution Planning Process
 - Forecasting Development
 - Grid Needs Identification
 - Solution Development
- Non-Wires Solution Examples
- Review Distribution Grid Needs

Guidelines



- Post comments and question in the chat
- Please feel free to speak up and engage throughout
- Please keep the discussion civil and respectful
- Take comments with positive intent

Introductions



In the chat, please send us:

- Name
- Organization
- What are you most interested in learning about in these workshops?

You can also send us more information at DSP@idahopower.com

Idaho Power Team



Name	Position	Name	Position
Jared Ellsworth	Transmission, Distribution & Resource Planning Director	Angelique Rood	Regional Manager
Jim Burdick	Distribution Planning Engineering Leader	Dena McFarlin	Regional Customer Relations Manager
Marc Patterson	Transmission & Distribution Strategy Engineer	Mike Ybarguen	Economic & Community Development Advisor
Tyson Kent	Distribution Planning Engineer	Danielle Ready	Education & Outreach Energy Advisor
Dan Johnston	Transmission & Distribution Strategy Engineer	Rodolfo Beltran	Key Account Energy Advisor
Alison Williams	Regulatory Policy & Strategy Advisor Regulatory Affairs	Duane Pearson	Agriculture Representative

Clean today. **Cleaner tomorrow.**[®]



Our Clean-Energy Goal





As Idaho Power continues serving customers and communities with **reliable, affordable** energy, we do so with an exciting goal:

Providing
100% clean energy by 2045.

Clean today. **Cleaner tomorrow.**[®]

Clean Energy

2021 Energy Mix



Data Source: U.S. Energy Information Administration

Idaho Power in Oregon



Oregon Customers **20,477**

4,000
SQUARE MILES

Peak Demand and Generation



1.7MW Oregon Customer Generation
(Net Metering)

142MW Oregon Small Generation

136MW Oregon Large Wind &
Geothermal

145MW Peak Demand

We Are Reliable



WE KEEP THE LIGHTS ON


99.9%

OF THE TIME

We Are Affordable




OUR PRICES ARE MORE THAN
20% BELOW
THE NATIONAL AVERAGE



INTRODUCING OUR NEW MOBILE APP!

Idaho Power customers can now
download the app to:


- Make quick and easy bill payments
- View billing and payment history
- Track power outages and view an in-app outage map
- Sign up for billing and payment programs
- Receive outage and billing push notifications
- Track energy use




Power Grid 101




Power Generation



Power Transmission



Distribution System





Distribution Components

- Substation
- Substation Transformer
 - Steps the voltage down from transmission voltages to distribution voltages
 - Has a voltage-regulating system to maintain distribution voltage



Distribution Components

- Distribution Circuit (Feeder)
 - Wires that transfer the electricity from the substation to the home or business.
 - These wires can be overhead or underground.





Distribution Components

- Service transformer
 - Steps distribution voltage down to service voltage for use by the customer
 - Can be overhead or underground



Distribution Components

- Other distribution components include:
 - Voltage regulators
 - Reclosers
 - Capacitors



Distribution Components



- Non-Wire Solution (NWS)
Examples include:
 - Batteries
 - Solar
 - Wind
- These are commercially available options
- Anticipate more options in the future



Capacity



The amount of power a piece of the grid can handle
The unit is the same as it is for power, megawatts (MW)



Planning for Capacity



Capacity Limits



Distribution System Growth

- Residential
- Small Commercial
- Large Commercial

- **Thermal Limit**
- **Planning Limit**



Capacity



Energy



The amount of power used in a given period of time:

- kilowatt-hour (kWh) = unit of measure for electrical energy



100-Watt
light bulb

×

10 hours

=

1 kWh

Energy vs Capacity Analogy




Capacity: 2 vehicles at a time



Energy: 1,000 vehicles pass the line in an hour

Demand (Load)

145MW, 7:00 pm Peak Demand in Oregon



Typical Units for Power Delivery





	Base Unit	Typical Unit
Voltage	Volt (V)	kilovolt (kV)*
Power	Watt (W)	megawatt (MW)**
Capacity	Watt (W)	megawatt (MW)**
Energy	Watt-hours (Wh)	kilowatt-hours (kWh)

kilo = 1,000

mega = 1,000,000

Distribution Planning Process



3 – 5 Year Process





Distribution Forecasting Development

- Historical Peak Demand
- Temperature Impact
- Growth from Customers
(residential/commercial/industrial)

Forecast Adjustments




- EV adoption
 - Presently 20 EVs with high forecast of 148 in 2026
- Customer Generation (aka net metering) adoption
 - Presently 1.7MW of generation capacity with a high forecast of 2.7MW in 2026 (mix of residential, irrigation, and commercial)

Low impact in the near-term forecast (2 - 4 years)

Load Forecast Example



Idaho Power Distribution Circuit Example




Distribution Grid Needs



Distribution grid needs drivers include:

- Growth and Reliability
 - Limited capacity
 - Low/high voltage
 - Frequent outages
- Asset Replacement
 - Signs of failure
 - Asset no longer supported by manufacturer
 - Line relocation due to road widening

Solution Development Toolbox



Tradition solutions



Non-Wire Solutions (NWS)






Distribution Grid Needs


Asset Replacement Grid Needs don't typically work well with Non-Wire Solutions (NWS)




Oregon Distribution System Investment 2023 – 2026



Distribution Capacity



Solution Evaluation Process



MOON42 End of Feeder PV Project



MOON42 End Of Feeder PV Project




NWS Example - Moon End of Feeder



A non-wires solution for mitigating low voltage at the end of a feeder

- Sustained seasonal low voltage at the end of a long radial feeder
- Traditional Solution: Reconductor
 - Estimated cost: **\$312k**
 - 13 customers ~90 kW peak demand
 - Voltage regulators and capacitors not an option
- Non-wire Solution: Photovoltaic
 - 18 kW solar installed at low voltage area to increase voltage
 - PV installation cost: \$43,250
 - Total Project cost: **\$132,500**
 - In service October 2016



NWS Example - Jordan Valley Project



Jordan Valley

NWS Example - Jordan Valley Project

- Traditional Project Costs \$860,000
- NWS Project Costs \$544,000
- Expected to defer project for 10 Years

Microgrid-Powered Services

1. Substation
2. Ambulance
3. Fuel
4. Medical Clinic
5. Water
6. Communications (Off Map)



NWS Example - Jordan Valley Project



What would this project accomplish

- Shave peak load to prevent transformer capacity overload
- Add microgrid to serve critical community load

What equipment would be installed?

- 70-kilowatt (kW) solar system with 250-kW battery system
- Distribution switches to isolate the microgrid area

Why did Idaho Power pick Jordan Valley for this project?

- Criteria that made Jordan Valley a good candidate for a microgrid:
 - Modest growth (1.75%)
 - Summer peak energy needs
 - Improve reliability

NWS Example - Jordan Valley Project



Why did Idaho Power Not Pursue the project?

- New load appeared (260kW)
 - Exceeded expected growth
 - Exceeded capability of Non-Wires solution
 - Cost prohibitive

NWS Example – WESR Battery Energy System



NWS Example - WESR Battery Energy System




Peak occurs summer at 9 p.m.

Modest growth <0.85% per year

Land area available for storage

Integrated Resource Plan (IRP) identified need for storage

WESR Storage Peak Shaving



NWS Example – WESR Battery System



Battery Project Details

- 3MW capacity 4-hour battery (12MWh)
- Expandable to 4MW capacity 4-hour battery (16MWh)
- Expected to defer project for 8 years

Traditional Project Cost - \$2,530,000

Deferring Project from 2023 to 2031 - \$1,816,000

- May reduce the overall cost and satisfy IRP system resource need

Review Distribution Grid Needs 2023 - 2026



Review Distribution Grid Needs 2027 - 2028



Detailed Distribution Grid Needs 2023 - 2028




Substation/Feeder Identifier	Project Type	Need Date	Grid Need - Traditional Solution	Traditional Project Cost
ADRN11	Reliability	4/1/2023	Line protection equipment does not record information - replace with modern smart recloser	\$21,000
VALE13	Reliability	5/1/2023	Limit outage impact - Add fuses	\$38,000
VALE15	Growth	5/1/2023	Low voltage on feeder - Add regulator	\$48,000
HFVY12	Growth	10/1/2023	Regulator planning capacity at limit - Upgrade regulator capacity	\$51,500
CWVY12	Growth	4/1/2024	Low voltage on feeder - Add regulator	\$58,000
HMDL12	Growth	5/1/2027	Feeder capacity at limit. The project requires 4.25 mile of distribution rebuild with a river crossing and other distribution devices.	\$1,074,000
HOLY13	Growth	10/1/2027	PAET12 planning feeder capacity at limit - Increase HOLY13 feeder capacity by rebuilding 3.9 miles of distribution with a river crossing and other distribution devices for a PAET12 load transfer.	\$897,500
NYSA T-061	Growth	5/1/2028	Transformer planning capacity at limit - Upgrade transformer capacity	\$1,716,000
JNTA T-061	Growth	5/1/2028	Transformer planning capacity at limit - Upgrade transformer capacity	\$294,000
JMSN T-061	Growth	5/1/2028	Transformer planning capacity at limit - Upgrade transformer capacity	\$837,600

Community Input



Please select your top three electricity considerations:



Next Steps



- What other data/information is needed to prepare for a meaningful discussion on potential NWS opportunities?
- There will be a document uploaded to the [Idaho Power DSP Website](#) identifying grid needs and the issue being addressed
- For the June 6th meeting, we will share the non-wire analysis for the identified grid needs and ask for input on those potential solutions and the community impacts

Input

