

**GENERATOR INTERCONNECTION  
FEASIBILITY STUDY REPORT**

for integration of the proposed

**400 MW [REDACTED] PROJECT  
(GI PROJECT #591)**

to the

**IDAHO POWER COMPANY ELECTRICAL SYSTEM**

in

**ELMORE COUNTY, IDAHO**

for

[REDACTED]

**Report v.0**

**March 31, 2021**

**OFFICIAL USE ONLY**

**DO NOT DUPLICATE, DISTRIBUTE, PUBLISH OR SHARE**

*This report contains Idaho Power Company Critical Energy Infrastructure Information (CEII).  
Distribution of this report must be limited to parties that have entered into a non-disclosure  
agreement with Idaho Power Company and have a need to know.*

## Table of Contents

<b>1.0</b>	<b>Introduction.....</b>	<b>3</b>
<b>2.0</b>	<b>Summary.....</b>	<b>4</b>
<b>3.0</b>	<b>Scope of Interconnection Feasibility Study .....</b>	<b>5</b>
<b>4.0</b>	<b>Contingent Facilities .....</b>	<b>5</b>
<b>5.0</b>	<b>Description of Proposed Generating Project.....</b>	<b>6</b>
<b>6.0</b>	<b>Energy Resource (ER) Interconnection Service.....</b>	<b>6</b>
<b>6.1</b>	<b>Description of Substation/Transmission Facilities .....</b>	<b>7</b>
<b>6.2</b>	<b>Description of Distribution Facilities.....</b>	<b>7</b>
<b>6.3</b>	<b>Short Circuit Study Results.....</b>	<b>8</b>
<b>6.4</b>	<b>Electric System Protection Results and Grounding Requirements .....</b>	<b>8</b>
<b>6.5</b>	<b>Energy Resource Cost Estimates .....</b>	<b>9</b>
<b>7.0</b>	<b>Network Resource (NR) Interconnection Service.....</b>	<b>10</b>
<b>7.1</b>	<b>Description of Power Flow Cases.....</b>	<b>10</b>
<b>7.2</b>	<b>Power Flow Analysis Results.....</b>	<b>10</b>
<b>7.3</b>	<b>Network Resource Transmission Upgrades.....</b>	<b>11</b>
<b>7.4</b>	<b>Network Resource Cost Estimate .....</b>	<b>12</b>
<b>8.0</b>	<b>Description of Operating Requirements.....</b>	<b>15</b>
<b>9.0</b>	<b>Conclusion .....</b>	<b>16</b>
	<b>APPENDIX A .....</b>	<b>17</b>
<b>A-1.0</b>	<b>Method of Study .....</b>	<b>17</b>
<b>A-2.0</b>	<b>Acceptability Criteria.....</b>	<b>17</b>
<b>A-3.0</b>	<b>Electrical System Protection Guidance .....</b>	<b>18</b>
<b>A-4.0</b>	<b>WECC Coordinated Off-Nominal Frequency Load Shedding and Restoration Requirements.....</b>	<b>18</b>

### OFFICIAL USE ONLY

*DO NOT DUPLICATE, DISTRIBUTE, PUBLISH OR SHARE*

*This report contains Idaho Power Company Critical Energy Infrastructure Information (CEII).  
Distribution of this report must be limited to parties that have entered into a non-disclosure  
agreement with Idaho Power Company and have a need to know.*

## 1.0 Introduction

██████████ has contracted with Idaho Power Company (“Transmission Provider”) to perform a Generator Interconnection Feasibility Study for the integration of the proposed 400 MW ██████████ project. The Project location is in Idaho Power Company’s (IPC’s) Capital Region in Elmore County, Idaho. The primary project latitude and ██████████. Additionally, a secondary project location latitude and longitude coordinates were also given and are ██████████. The project is Generation Interconnect (GI) queue number 591 (GI #591). The project has chosen in the Feasibility Study to be studied as both an Energy Resource (ER) Interconnection Service and a Network Resource (NR) Interconnection Service.

The Project has applied to connect to the Idaho Power’s transmission system for an injection of 400 MW at a single Point of Interconnection (POI) at 230kV for the primary POI and at 138 kV for the secondary POI. The primary POI is located on IPC’s ██████████ 230kV line and the secondary POI is located on IPC’s ██████████ 138 kV line.

IPC projects queue GI #530, GI #551, GI #557, GI #561, GI #567, GI #568, GI #570 and GI #588 are senior queued projects in the affected area of IPC’s transmission system. Idaho Power studied GI #591 with all Network Upgrades identified for GI #530, GI #551, GI #557, GI #561, GI #567, GI #568, GI #570 and GI #588 modeled as in service (Potential Contingent Facilities). No Contingent Facilities of the Network Transmission facility upgrades required by senior queue projects and their conceptual costs, have been preliminarily identified to be required for GI #591 Network Resource Interconnection Service. These Contingent Facilities will be reviewed further and finalized during the System Impact Study. GI #590 was not included in the modeling for GI #591 as the project location is the same.

This report documents the basis for and the results of this Feasibility Study for the GI #591 Generation Interconnection Customer. The report describes the proposed project, the determination of the project interconnection requirements and estimated costs for integration of the project to the Transmission Provider transmission system. This report satisfies the feasibility study requirements of the Idaho Power Tariff.

### **OFFICIAL USE ONLY**

**DO NOT DUPLICATE, DISTRIBUTE, PUBLISH OR SHARE**

*This report contains Idaho Power Company Critical Energy Infrastructure Information (CEII). Distribution of this report must be limited to parties that have entered into a non-disclosure agreement with Idaho Power Company and have a need to know.*

## 2.0 Summary

The feasibility of interconnecting the GI #591 400 MW generation project to the Transmission Provider's transmission system at either of the proposed Points of Interconnection (POI) was evaluated. GI #591 can be interconnected to the Idaho Power transmission system at the primary POI only. Connection to the proposed secondary POI was found to not be feasible. The two POIs evaluated are located on IPC's [REDACTED] 230kV line and the [REDACTED] 138 kV line. Connection to the [REDACTED] 138 kV line is not feasible.

A System Impact Study is required to determine if any additional network upgrades are required to integrate this project into the IPCo transmission system and to evaluate full system impacts (thermal, voltage, transient stability, reactive margin). Generator interconnection service (either as an Energy Resource or a Network Resource) does not in any way convey any right to deliver electricity to any specific customer or point of delivery.

GI #591 will be required to control voltage in accordance with a voltage schedule as provided by Idaho Power Grid Operations. GI #591 will be required to manage the real power output of their generation project at the POI. Also, it may be beneficial for [REDACTED] for their own modeling compliance requirements, to install additional PMU devices at their facilities to monitor the generation source(s).

The total "Energy Resource Interconnection Service" generation interconnection preliminary cost estimate to interconnect the project to the primary study POI is as follows:

<b>ER</b>	<b>Primary POI</b>	<b>Secondary POI</b>
400 MW	<b>\$15,119,788</b>	<b>NA</b>

See Section 6.5 Energy Resource Cost Estimate for the required Energy Resource facilities and cost breakdowns.

The total "Network Resource Interconnection Service" generation interconnection preliminary cost estimate to interconnect the [REDACTED] project is as follows:

<b>NR</b>	<b>Primary POI</b>	<b>Secondary POI</b>
400 MW	<b>\$62,576,272</b>	<b>NA</b>
330 MW	<b>\$61,737,260</b>	<b>NA</b>

See Section 7.4 Network Resource Cost Estimate for the required Network Resource facilities and cost breakdowns. The cost estimate includes a 20% contingency and 7.25% overhead. These are cost estimates only and final charges to the customer will be based on the actual

### **OFFICIAL USE ONLY**

**DO NOT DUPLICATE, DISTRIBUTE, PUBLISH OR SHARE**

*This report contains Idaho Power Company Critical Energy Infrastructure Information (CEII). Distribution of this report must be limited to parties that have entered into a non-disclosure agreement with Idaho Power Company and have a need to know.*

construction costs incurred. It should be noted that the preliminary cost estimates do not include the cost of the customer's owned equipment.

██████████ has applied for connection of 400 MW. Idaho Power has a Most Severe Single Contingency (MSSC) of █████ MW. A single contingency cannot result in the loss of more than █████ MW. If the project connects at 400 MW, two independent circuits will be needed to connect into a minimum of a 4-position ring bus to ensure that no more than █████ MW can be lost due to a single contingency. Additionally, the project itself would need to be separated internally to break up the generation such that no more than █████ MW could be lost due to a single contingency. The Single Line Diagram supplied does not indicate the 400 MW project is designed in this manner. Internal redesign and the additional line would be necessary to connect as a 400 MW network resource.

The schedule for designing, procuring, and constructing facilities will be developed and optimized during the Facility Study should the generation interconnection customer choose to move to that study phase of the interconnection process.

### **3.0 Scope of Interconnection Feasibility Study**

The Interconnection Feasibility Study was done and prepared in accordance with the Transmission Provider's Standard Generator Interconnection Procedures to provide a preliminary evaluation of the feasibility of the interconnection of the proposed generating project to the Idaho Power system. As listed in the Interconnection Feasibility Study agreement, the Interconnection Feasibility Study report provides the following information:

- preliminary identification of any circuit breaker short circuit capability limits exceeded because of the interconnection;
- preliminary identification of any thermal overload or voltage limit violations resulting from the interconnection; and
- preliminary description and non-binding estimated cost of facilities required to interconnect the Large Generating Facility to the IPC System and to address the identified short circuit and power flow issues.

All other proposed Generation projects prior to this project in the Generator Interconnect queue were considered in this study. A current list of these projects can be found in the Generation Interconnection folder located on the Idaho Power web site at the link shown below:

<http://www.oatioasis.com/ipco/index.html>.

### **4.0 Contingent Facilities**

GI #591 Energy Resource, ER, service at the 230kV POI is not contingent upon upgrades associated with any senior queued project.

#### **OFFICIAL USE ONLY**

*DO NOT DUPLICATE, DISTRIBUTE, PUBLISH OR SHARE*

*This report contains Idaho Power Company Critical Energy Infrastructure Information (CEII). Distribution of this report must be limited to parties that have entered into a non-disclosure agreement with Idaho Power Company and have a need to know.*

IPC projects queue GI #530, GI #551, GI #557, GI #561, GI #567, GI #568, GI #570 and GI #588 are senior queued project in the affected area of IPC's transmission system. Idaho Power studied GI #591 with all Network Upgrades identified for GI #530, GI #551, GI #557, GI #561, GI #567, GI #568, GI #570 and GI #588 modeled as in service (Potential Contingent Facilities). No Contingent Facilities of the Network Transmission facility upgrades required by senior queue projects and their conceptual costs, have been preliminarily identified to be required for GI #591 Network Resource Interconnection Service. Contingent Facilities will be reviewed further and finalized during the System Impact Study. Changes to senior queued projects including in-service date and withdrawal from the queue, may trigger a restudy associated with GI #591 Network Resource, NR, service, (some or all the network upgrades identified for GI #530, GI #551, GI #557, GI #561, GI #567, GI #568, GI #570 and GI #588 may be required by GI #591. GI #590 was not included in the modeling for GI #591 as the project location is the same.

## 5.0 Description of Proposed Generating Project

### Assumptions

The primary point of interconnection for GI #591 is located on IPC's [REDACTED] 230kV line and the secondary point of interconnection is on IPC's [REDACTED] 138 kV line. GI #591 Project's maximum generation is 400 MW. The Project's projected Commercial Operation Date (COD) is [REDACTED].

The GI #591 supplied Single Line Diagram indicates:

- [REDACTED] GSU transformers with a [REDACTED] MVA capacity each
- Total plant export limited to 400 MW at the 230kV primary POI
- All generation in voltage regulation (Reactive capability used to regulate voltage – supply/absorb reactive)

## 6.0 Energy Resource (ER) Interconnection Service

Energy Resource (ER) Interconnection Service allows the Interconnection Customer to connect its Generating Facility to Transmission Provider's transmission system and to be eligible to deliver electric output using firm or non-firm transmission capacity on an as available basis.

The GI #591 project has applied to connect to the Idaho Power transmission system for an injection of 400 MW with a 230kV interconnection at the primary point of interconnection on IPC's [REDACTED] line and a 138 kV point of connection at the secondary point of interconnection on IPC's [REDACTED] line. All generation projects in the area ahead of this project in the IPC generation queue and their associated transmission system improvements, with the exception of GI #590, were modeled in a

### **OFFICIAL USE ONLY**

**DO NOT DUPLICATE, DISTRIBUTE, PUBLISH OR SHARE**

*This report contains Idaho Power Company Critical Energy Infrastructure Information (CEII). Distribution of this report must be limited to parties that have entered into a non-disclosure agreement with Idaho Power Company and have a need to know.*

preliminary power flow analysis to evaluate the feasibility of interconnecting GI #591.

### 6.1 Description of Substation/Transmission Facilities

As an Energy Resource, a Transmission Service Request will be required to determine the specific Network Upgrades required to deliver the project output to a designated point of delivery. A System Impact Study will be required to determine the specific network upgrades required to integrate the project. Listed below are the required transmission facilities to interconnect the Project.

**For 400 MW injected at the primary point of interconnection located on IPC's [REDACTED] 230kV line:**

#### Substation/Transmission Interconnection Facilities:

The proposed interconnection will require:

- 230kV 3-position ring bus interconnection substation
- auto-bypass protection functionality for the [REDACTED] series capacitors.

The actual station layout and detailed equipment requirements will be determined in the Facility Study should the interconnection customer choose to move to that study phase of the interconnection process.

#### Transmission Interconnection Facilities:

The proposed interconnection will require:

- Modify [REDACTED] 230 kV series capacitor [REDACTED]
  - Bypass section 2
  - Rebuild section 1 to [REDACTED]
- Add a [REDACTED] 230 kV series capacitor [REDACTED] at [REDACTED] line [REDACTED]

**For 400 MW injected at the secondary point of interconnection located on IPC's [REDACTED] 138 kV line:**

This is not feasible

### 6.2 Description of Distribution Facilities

No distribution facilities are directly impacted by this project.

#### OFFICIAL USE ONLY

DO NOT DUPLICATE, DISTRIBUTE, PUBLISH OR SHARE

*This report contains Idaho Power Company Critical Energy Infrastructure Information (CEII). Distribution of this report must be limited to parties that have entered into a non-disclosure agreement with Idaho Power Company and have a need to know.*

### 6.3 Short Circuit Study Results

- The facility does not exceed any of the breaker ratings on the Midpoint or Boise Bench terminals.

Fault Study (w/o GI #591)			
Location	SLG (A)	LTL (A)	3PH (A)
██████████ Bus	32393.6	25947.2	28449.8
██████████ Bus	28262.9	24418.6	28075.9

Fault Study (w/ GI #591)			
Location	SLG (A)	LTL (A)	3PH (A)
██████████ Bus	33192.2	26537	29554.4
██████████ Bus	28443.3	24989.9	28129.4

### 6.4 Electric System Protection Results and Grounding Requirements

For 230kV line protection, the Transmission Provider's System Protection Department utilizes permissive and line differential protection schemes integrated with our existing digital communication infrastructure. Digital communication infrastructure for the interconnection customer's 230kV line terminal will be the responsibility of said interconnection customer.

#### **OFFICIAL USE ONLY**

**DO NOT DUPLICATE, DISTRIBUTE, PUBLISH OR SHARE**

*This report contains Idaho Power Company Critical Energy Infrastructure Information (CEII). Distribution of this report must be limited to parties that have entered into a non-disclosure agreement with Idaho Power Company and have a need to know.*



## 6.5 Energy Resource Cost Estimates

In Table 1 below a summary is provided of the generation interconnection facilities and conceptual costs required to interconnect the GI #591 project to the Transmission Provider's transmission system as an Energy Resource with 400 MW injected at the primary point of interconnection located on IPC's ██████████ 230kV line.

<b>GI #591 ██████████ Project</b>	
<b>400 MW injected at the primary point of interconnection located on IPC's ██████████ 230kV line</b>	
<b>Energy Resource Generation Interconnection Facilities</b>	
<b>Direct Assigned</b>	<b>Cost</b>
<b>Approximately 20% of a new 230kV 3 position ring bus interconnection station</b> Air-break switches, breakers, metering, relaying, etc.	\$669,617.00
<b>Network Assigned</b>	
<b>Approximately 80% of a new 230kV 3 position ring bus interconnection station</b> Air-break switches, breakers, metering, relaying, etc.	\$2,678,470.00
Auto-bypass protection functionality for the ██████████ ████████ series capacitors	\$400,000.00
Modify ██████████ 230 kV series capacitor ██████████ ████████. Bypass section 2 Rebuild section 1 to ██████████	\$1,000,000.00
Add a ██████████ 230 kV series capacitor ██████████ at the ████████████████████ line ██████████ ████████	\$7,000,000.00
<b>Subtotal</b>	<b>\$11,748,087.00</b>
Contingencies (~20.0%) (1)	\$2,349,617.40
<b>Subtotal</b>	<b>\$14,097,704.40</b>
Overheads (~7.25%) (2)	\$1,022,083.57
<b>Energy Resource – Total Estimated Cost (3)</b>	<b>\$15,119,787.97</b>

Table 1. Estimated GI #591 Project's Energy Resource Generation Interconnection Costs. 400 MW injection at primary point of interconnection.

### OFFICIAL USE ONLY

DO NOT DUPLICATE, DISTRIBUTE, PUBLISH OR SHARE

This report contains Idaho Power Company Critical Energy Infrastructure Information (CEII).  
Distribution of this report must be limited to parties that have entered into a non-disclosure  
agreement with Idaho Power Company and have a need to know.

- (1) Contingency is added to cover the unforeseen costs in the estimate. These costs can include unidentified design components, material cost increases, labor estimate shortfalls, etc.
- (2) Overhead costs cover the indirect costs associated with the Project.
- (3) This cost estimate includes direct equipment, material, labor, and overheads as shown.
  - Note that these estimates do not include the cost of the customer's equipment/facilities or required communication circuits for SCADA, PMU, and metering.
  - Note that the overhead rates are subject to change during the year.
  - These are estimated costs only and final charges to the customer will be based on the actual construction costs incurred.
  - These are non-binding conceptual level cost estimates that will be further refined upon the request and completion of the Facility Study.

The schedule for designing, procuring, and constructing facilities will be developed and optimized during the Facility Study should the generation interconnection customer choose to move to that study phase of the interconnection process.

## **7.0 Network Resource (NR) Interconnection Service**

Network Resource Interconnection Service allows the Interconnection Customer to integrate its Generating Facility with the Transmission Provider's Transmission System in a manner comparable to that in which the Transmission Provider integrated its generating facilities to serve native load customers. The transmission system is studied under a variety of conditions to determine the transmission improvements/upgrades which are necessary. Network Resource Interconnection Service in and of itself does not convey Transmission Service.

### **7.1 Description of Power Flow Cases**

For the Network Resource Interconnection Service study, two power flow cases were used to study the Transmission Provider's transmission system with westbound and eastbound transmission flows to determine the required Network Transmission Upgrades.

The WECC 2020 Heavy Summer case was chosen as a power flow base case for the study. The case was modified to represent a summer month with high west to east (eastbound) transfers across [REDACTED].

For the second case, a WECC 2019 Light Winter operating case, was modified to represent a shoulder month condition with high east to west (westbound) transfers across [REDACTED].

### **7.2 Power Flow Analysis Results**

Power Flow cases were run for the primary point of interconnection for GI #591 located on IPC's [REDACTED] 230kV line and the secondary point of interconnection on IPC's [REDACTED] 138 kV line. Two cases were run, reducing the size for the GI #591 injection, in an effort to reduce network upgrades required. [REDACTED]. In planning studies, a single contingency cannot result in a loss of greater than [REDACTED] MW. In order to prevent this, if

#### **OFFICIAL USE ONLY**

**DO NOT DUPLICATE, DISTRIBUTE, PUBLISH OR SHARE**

*This report contains Idaho Power Company Critical Energy Infrastructure Information (CEII). Distribution of this report must be limited to parties that have entered into a non-disclosure agreement with Idaho Power Company and have a need to know.*



3. Rebuild the 230 kV [REDACTED] line to [REDACTED].
4. Add protection auto bypass functionality to [REDACTED] 230 kV series capacitors.

Primary point of interconnection, 330MW injection

1. Modify [REDACTED] 230 kV series capacitor [REDACTED]
  - Bypass section 2
  - Rebuild section 1 to [REDACTED]
2. Add a [REDACTED] 230 kV series capacitor [REDACTED] at th [REDACTED] [REDACTED] line [REDACTED].
3. Rebuild the 230 kV [REDACTED] line to [REDACTED].
4. Add protection auto bypass functionality to [REDACTED] 230 kV series capacitors.

IPC projects queue GI #530, GI #551, GI #557, GI #561, GI #567, GI #568, GI #570 and GI #588 are senior queued project in the affected area of IPC's transmission system. Idaho Power studied GI #591 with all Network Upgrades identified for GI #530, GI #551, GI #557, GI #561, GI #567, GI #568, GI #570 and GI #588 modeled as in service (Potential Contingent Facilities). No Contingent Facilities of the Network Transmission facility upgrades required by senior queue projects and their conceptual costs, have been preliminarily identified to be required for GI #591 Network Resource Interconnection Service. These Contingent Facilities will be reviewed further and finalized during the System Impact Study. Changes to senior queued projects including in-service date and withdrawal from the queue, may trigger a restudy associated with GI #591 Network Resource, NR, service, (some or all the network upgrades identified for senior queued projects may be required by GI #591. GI #590 was not included in the modeling for GI #591 as the project location is the same.

#### 7.4 Network Resource Cost Estimate

In Table 2 below a summary is provided of the generation interconnection facilities and conceptual costs required to interconnect the GI #591 project to the Transmission Provider's transmission system as a Network Resource with 400 MW injected at the primary point of interconnection located on IPC's [REDACTED] 230kV line.

**GI #591 [REDACTED] Project**  
**400 MW injected at the primary point of interconnection located on IPC's [REDACTED] 230kV line**  
**Network Resource Generation Interconnection Facilities**

#### **OFFICIAL USE ONLY**

*DO NOT DUPLICATE, DISTRIBUTE, PUBLISH OR SHARE*

*This report contains Idaho Power Company Critical Energy Infrastructure Information (CEII). Distribution of this report must be limited to parties that have entered into a non-disclosure agreement with Idaho Power Company and have a need to know.*

<b>Direct Assigned</b>	<b>Cost</b>
<b>Approximately 20% of a new 230kV 4 position ring bus interconnection station</b> Air-break switches, breakers, metering, relaying, etc.	\$800,000.00
<b>Network Assigned</b>	
<b>Approximately 80% of a new 230kV 4 position ring bus interconnection station</b> Air-break switches, breakers, metering, relaying, etc.	\$3,200,000.00
Auto-bypass protection functionality for the [REDACTED] series capacitors	\$400,000.00
Modify [REDACTED] 230 kV series capacitor [REDACTED]	\$1,000,000.00
Add a [REDACTED] 230 kV series capacitor [REDACTED] at the [REDACTED] line [REDACTED]	\$7,000,000.00
Rebuild the 230 kV [REDACTED] line to [REDACTED]	\$36,221,812.00
<b>Subtotal</b>	<b>\$48,621,812.00</b>
Contingencies (~20.0%) (1)	\$9,724,362.40
<b>Subtotal</b>	<b>\$58,346,174.40</b>
Overheads (~7.25%) (2)	\$4,230,097.64
<b>Energy Resource – Total Estimated Cost (3)</b>	<b>\$62,576,272.04</b>

Table 2. Estimated GI #591 Project's Network Resource Generation Interconnection Costs. 400 MW injection at primary point of interconnection.

(1) Contingency is added to cover the unforeseen costs in the estimate. These costs can include unidentified design components, material cost increases, labor estimate shortfalls, etc.

(2) Overhead costs cover the indirect costs associated with the Project.

(3) This cost estimate includes direct equipment, material, labor, and overheads as shown.

- Note that these estimates do not include the cost of the customer's equipment/facilities or required communication circuits for SCADA, PMU, and metering.
- Note that the overhead rates are subject to change during the year.
- These are estimated costs only and final charges to the customer will be based on the actual construction costs incurred.
- These are non-binding conceptual level cost estimates that will be further refined upon the request and completion of the Facility Study.

In Table 3 below a summary is provided of the generation interconnection facilities and

**OFFICIAL USE ONLY**

**DO NOT DUPLICATE, DISTRIBUTE, PUBLISH OR SHARE**

*This report contains Idaho Power Company Critical Energy Infrastructure Information (CEII). Distribution of this report must be limited to parties that have entered into a non-disclosure agreement with Idaho Power Company and have a need to know.*

conceptual costs required to interconnect the GI #591 project to the Transmission Provider's transmission system as a Network Resource with 330 MW injected at the primary point of interconnection located on IPC's [REDACTED] 230kV line.

<b>GI #591 [REDACTED] Project</b>	
<b>330 MW injected at the primary point of interconnection located on IPC's [REDACTED] 230kV line</b>	
<b>Network Resource Generation Interconnection Facilities</b>	
<b>Direct Assigned</b>	<b>Cost</b>
<b>Approximately 20% of a new 230kV 3 position ring bus interconnection station</b> Air-break switches, breakers, metering, relaying, etc.	\$669,617.00
<b>Network Assigned</b>	
<b>Approximately 80% of a new 230kV 3 position ring bus interconnection station</b> Air-break switches, breakers, metering, relaying, etc.	\$2,678,470.00
Auto-bypass protection functionality for the [REDACTED] series capacitors	\$400,000.00
Modify [REDACTED] 230 kV series capacitor [REDACTED].	\$1,000,000.00
Add a [REDACTED] 230 kV series capacitor [REDACTED] at the [REDACTED] line [REDACTED].	\$7,000,000.00
Rebuild the 230 kV [REDACTED] line to [REDACTED].	\$36,221,812.00
<b>Subtotal</b>	<b>\$47,969,899.00</b>
Contingencies (~20.0%) (1)	\$9,593,979.80
<b>Subtotal</b>	<b>\$57,563,878.80</b>
Overheads (~7.25%) (2)	\$4,173,381.21
<b>Energy Resource – Total Estimated Cost (3)</b>	<b>\$61,737,260.01</b>

Table 3. Estimated GI #591 Project's Network Resource Generation Interconnection Costs. 330 MW injection at primary point of interconnection.

(1) Contingency is added to cover the unforeseen costs in the estimate. These costs can include unidentified design components, material cost increases, labor estimate shortfalls, etc.

**OFFICIAL USE ONLY**

**DO NOT DUPLICATE, DISTRIBUTE, PUBLISH OR SHARE**

*This report contains Idaho Power Company Critical Energy Infrastructure Information (CEII). Distribution of this report must be limited to parties that have entered into a non-disclosure agreement with Idaho Power Company and have a need to know.*

- (2) Overhead costs cover the indirect costs associated with the Project.
- (3) This cost estimate includes direct equipment, material, labor, and overheads as shown.
- Note that these estimates do not include the cost of the customer's equipment/facilities or required communication circuits for SCADA, PMU, and metering.
  - Note that the overhead rates are subject to change during the year.
  - These are estimated costs only and final charges to the customer will be based on the actual construction costs incurred.
  - These are non-binding conceptual level cost estimates that will be further refined upon the request and completion of the Facility Study.

The schedule for designing, procuring, and constructing facilities will be developed and optimized during the Facility Study should the generation interconnection customer choose to move to that study phase of the interconnection process.

## 8.0 Description of Operating Requirements

It is the generation project's responsibility to provide reactive power capability of the project to have a power factor operating range of at least 0.95 leading (absorbing) to at least 0.95 lagging (supplying) at the POI over the range of real power output (up to maximum output of the project).

Identification of any additional equipment required at the plant to meet Idaho Power reactive power capability interconnection requirements will be provided in the System Impact Study if the generation interconnection customer chooses to move to the next study phase of the interconnection process.

GI #591 will be required to control voltage in accordance with a voltage schedule as provided by Idaho Power Grid Operations, and GI#591 will be required to manage the real power output of their stated generation at the project's POI.

The project(s) is required to comply with the applicable Voltage and Current Distortion Limits found in IEEE Standard 519-1992 *IEEE Recommended Practices and Requirements for Harmonic Control in Electrical Power Systems*.

Installation of phasor measurement unit devices at the POI and maintenance costs associated with communication circuits needed to stream PMU data will also be required to be provided to interconnect GI #591. The specific costs associated with the IPC requirements for interconnection customers with aggregate facilities larger than 20 MW to provide PMU data to IPC will be identified in the Facility Study should the generation interconnection customer choose to proceed to that phase of the interconnection process. Also, it may be beneficial for [REDACTED] for their own modeling compliance requirements, to install additional PMU devices at their facilities to monitor the generations sources separately.

Additional operating requirements for this project may be identified in the System Impact study when it is performed.

### **OFFICIAL USE ONLY**

**DO NOT DUPLICATE, DISTRIBUTE, PUBLISH OR SHARE**

*This report contains Idaho Power Company Critical Energy Infrastructure Information (CEII). Distribution of this report must be limited to parties that have entered into a non-disclosure agreement with Idaho Power Company and have a need to know.*

**9.0 Conclusion**

GI #591 can be interconnected to the Idaho Power transmission system at the primary POI on IPC's [REDACTED] 230 kV line. Interconnection at the secondary POI on IPC's [REDACTED] 138 kV line is not feasible.

Interconnection requirements detailed in Section 6.5 are required to interconnect the project as an Energy Resource at the 230kV POIs given.

<b>ER</b>	<b>Primary POI</b>	<b>Secondary POI</b>
400 MW	<b>\$15,119,788</b>	<b>NA</b>

If the project connects as a Network Resource, the cost to integrate the project are estimated to be:

<b>NR</b>	<b>Primary POI</b>	<b>Secondary POI</b>
400 MW	<b>\$62,576,272</b>	<b>NA</b>
330 MW	<b>\$61,737,260</b>	<b>NA</b>

Details are given in section 7.4. For the project to connect as NR, the [REDACTED] MW MSSC requirement would need to be resolved. The Network Resource connection is also reliant on network facility upgrades identified in senior queued generation interconnection.

IPC projects queue GI #530, GI #551, GI #557, GI #561, GI #567, GI #568, GI #570 And GI #588 are senior queued project in the affected area of IPC's transmission system. Idaho Power studied GI #590 with all Network Upgrades identified for GI #530, GI #551, GI #557, GI #561, GI #567, GI #568, GI #570 and GI #588 modeled as in service (Potential Contingent Facilities). No Contingent Facilities of the Network Transmission facility upgrades required by senior queue projects and their conceptual costs, have been preliminarily identified to be required for GI #591 Network Resource Interconnection Service. These Contingent Facilities will be reviewed further and finalized during the System Impact Study.

A System Impact Study is required to determine the specific Transmission Network Upgrades required to integrate the project as a Network Resource and to evaluate the system impacts (thermal overload, voltage, transient stability, reactive margin). Generator interconnection service (either as an Energy Resource or a Network Resource) does not in any way convey any right to deliver electricity to any specific customer or point of delivery. A Transmission Service Request will be required to study the Transmission System Impacts.

**OFFICIAL USE ONLY**

*DO NOT DUPLICATE, DISTRIBUTE, PUBLISH OR SHARE*

*This report contains Idaho Power Company Critical Energy Infrastructure Information (CEII). Distribution of this report must be limited to parties that have entered into a non-disclosure agreement with Idaho Power Company and have a need to know.*



## APPENDIX A

### A-1.0 Method of Study

The Feasibility Study plan inserts the Project up to the maximum requested injection into the selected Western Electricity Coordinating Council (WECC) power flow case and then, using Power World Simulator or GE's Positive Sequence Load Flow (PSLF) analysis tool, examines the impacts of the new resource on Idaho Power's transmission system (lines, transformers, etc.) within the study area under various operating and outage scenarios. The WECC and Idaho Power reliability criteria and Idaho Power operating procedures were used to determine the acceptability of the configurations considered. The WECC case is a recent case modified to simulate stressed but reasonable pre-contingency energy transfers utilizing the IPC system. For distribution feeder analysis, Idaho Power utilizes DNV·GL's Synergi Electric software and EPRI's OpenDSS software.

### A-2.0 Acceptability Criteria

The following acceptability criteria were used in the power flow analysis to determine under which system configuration modifications may be required:

The continuous rating of equipment is assumed to be the normal thermal rating of the equipment. This rating will be as determined by the manufacturer of the equipment or as determined by Idaho Power. Less than or equal to 100% of continuous rating is acceptable.

Idaho Power's Voltage Operating Guidelines were used to determine voltage requirements on the system. These states, in part, that distribution voltages, under normal operating conditions, are to be maintained within plus or minus 5% (0.05 per unit) of nominal everywhere on the feeder. Therefore, voltages greater than or equal to 0.95 pu voltage and less than or equal to 1.05 pu voltage are acceptable.

Voltage flicker during starting or stopping the generator is limited to 5% as measured at the point of interconnection, per Idaho Power's T&D Advisory Information Manual.

Idaho Power's Reliability Criteria for System Planning was used to determine proper transmission system operation.

All customer generation must meet IEEE 519 and ANSI C84.1 Standards.

All other applicable national and Idaho Power standards and prudent utility practices were used to determine the acceptability of the configurations considered.

The stable operation of the system requires an adequate supply of volt-amperes reactive (VAr or VARs) to maintain a stable voltage profile under both steady-state and dynamic system conditions. An inadequate supply of VARs will result in voltage decay or even collapse under the worst conditions.

Equipment/line/path ratings used will be those that are in use at the time of the study or that

### OFFICIAL USE ONLY

*DO NOT DUPLICATE, DISTRIBUTE, PUBLISH OR SHARE*

*This report contains Idaho Power Company Critical Energy Infrastructure Information (CEII). Distribution of this report must be limited to parties that have entered into a non-disclosure agreement with Idaho Power Company and have a need to know.*

are represented by IPC upgrade projects that are either currently under construction or whose budgets have been approved for construction in the near future. All other potential future ratings are outside the scope of this study. Future transmission changes may, however, affect current facility ratings used in the study.

### **A-3.0 Electrical System Protection Guidance**

IPC requires electrical system protection per Facility Connection Requirements found on the Idaho Power Web site,

<https://docs.idahopower.com/pdfs/BusinessToBusiness/FacConnReq.pdf>

### **A-4.0 WECC Coordinated Off-Nominal Frequency Load Shedding and Restoration Requirements**

IPC requires frequency operational limits to adhere to WECC Under-frequency and Over-frequency Limits per the WECC Coordinated Off-Nominal Frequency Load Shedding and Restoration Requirements available upon request.

#### **OFFICIAL USE ONLY**

**DO NOT DUPLICATE, DISTRIBUTE, PUBLISH OR SHARE**

*This report contains Idaho Power Company Critical Energy Infrastructure Information (CEII).  
Distribution of this report must be limited to parties that have entered into a non-disclosure  
agreement with Idaho Power Company and have a need to know.*

## Revision History

<b>Date</b>	<b>Revision</b>	<b>Initials</b>	<b>Summary of Changes</b>
03/31/2021	0	PMA	Initial Feasibility Study Report
04/02/2021	1	PMA	Incorporate comments from internal review

**OFFICIAL USE ONLY**

**DO NOT DUPLICATE, DISTRIBUTE, PUBLISH OR SHARE**

*This report contains Idaho Power Company Critical Energy Infrastructure Information (CEII).  
Distribution of this report must be limited to parties that have entered into a non-disclosure  
agreement with Idaho Power Company and have a need to know.*