

# Meeting No. 2 Reference Guide

**2025-2026**

© 2025 Idaho Power



# TABLE OF CONTENTS

Table of Contents .....	i
Meeting No. 2 Reference Guide—West Central Mountains Electrical Plan (WCMEP)	
Update .....	1
Mapping Requirements .....	1
In-Scope Line Voltages.....	1
Out-of-Scope Line Voltages .....	1
Distribution Substation Connections .....	2
Reliability Criteria .....	3
Appendix D — Mapping Handout.....	1



# MEETING NO. 2 REFERENCE GUIDE—WEST CENTRAL MOUNTAINS ELECTRICAL PLAN (WCMEP) UPDATE

## Mapping Requirements

### 2025 WCMEP Update Required Electrical Infrastructure at Buildout

- Two Source Substations
  - At least one high voltage transmission line connection per source substation
- 4 Distribution Substations
  - 138 kV transmission lines connecting distribution substations to source substations or another distribution substation

### *In-Scope Line Voltages*

- High voltage transmission lines: 230 kV
- Transmission lines: 138 kV

### *Out-of-Scope Line Voltages*

- 500 kV high voltage transmission lines
- 69 kV transmission lines
- 12.5 kV–34.5 kV distribution lines

### Notes

---

---

---

---

---

---

---


---

---


---

## Distribution Substation Connections

- **Radial** — A substation connected to a single transmission line. Radial connections have a lower cost, smaller footprint and lower reliability than other options.



- **In-and-Out** — One transmission line entering a substation and a second transmission line leaving a substation. In-and-out connections are more expensive, but result in higher reliability. The in-and-out can be built as a double circuit transmission line on a single set of poles or as two separate lines.




## Reliability Criteria

(N-1) Criteria:


- 'N' stands for 'normal' and represents the system operating in a normal configuration
- (N - 1) indicates that the system is operating normally, but with the removal of a single transmission line or transformer

Example of Acceptable N - 1 Scenario



While 138 kV transmission lines typically have a capacity 200 MW, the sections of transmission lines that connect to the source substations can be rebuilt with larger conductor so that they have a capacity of 280 MW.

Example of an Unacceptable N - 1 Scenario



In this scenario, the section of transmission line circled in red would exceed the capacity of the larger conductor which has a rating of 280 MW.



## Appendix D — Mapping Handout

# Mapping Reference — WCMEP Update 2025

---

**Committee Mapping Goal:** Propose a single preferred site for each future source substation, distribution substation, and connecting transmission lines. Identified alternative sites will also be helpful.

**Step 1:** Review and confirm or adjust the 2014 WCMEP proposed **source substation** site

- **Smiths Ferry Area** Source Substation
  - The 2014 WCMEP Committee provided a preferred location in Washington County and an alternate location near Smiths Ferry.

**Step 2:** Propose sites for new **source substation**

- **West McCall Area** Source Substation
  - Idaho Power owns 4 acres of land in the area of the proposed distribution substation 4.
  - Idaho Power will need 5-10 acres of land for this source substation.

**Step 3:** Confirm or propose at least one **high voltage transmission line route** to each source substation

**Step 4:** Confirm or adjust 2014 WCMEP **distribution substation** sites

- Distribution Substation 1 (Placerville Area)
- Distribution Substation 2 (Indian Valley Area)
- Distribution Substation 3 (Donnelly Area)


**Step 5:** Propose site for new **distribution substation**

- Distribution Substation 4 (West McCall Area)

**Step 6:** Confirm or propose **138 kV transmission line routes** connecting distribution substations to either a source substation or another distribution substation.

**Step 7:** Propose the following required **138 kV transmission line routes**

- Additional line from Horse Flat to Starkey
- Additional line from McCall area to Boulder or Lake Fork



Voltage (kV)	Capacity (MW)	Typical Height (feet)	Right-of-Way (feet)	Cost (per mile)
500	1,500	150	160-250	\$ 5M-\$5.5M
230	500	100–120	60–120	\$2M–\$2.5M
138	200	65–85	50–100	\$1M–\$1.5M
69	70	58	50	\$400k–\$500k

Substation Type	Capacity (MW)	Area (acres)	Cost
Source	200–600	5–10	\$15M–\$30M
Distribution	5–88	3–4	\$11M–\$13M

