

A1 A2 Efficiency Requirements and Incentive Level

Equipment Type	Size Category (Single- and Three-Phase Units)	Sub-Category	Minimum Efficiency Requirement and Incentive	
			Consortium for Energy Efficiency (CEE) Tier 1	Consortium for Energy Efficiency (CEE) Tier 2
Unitary Commercial Air Conditioners (AC), Air-cooled (Cooling Mode)	ANY SIZE	Split system and single package	\$25/ton*	\$50/ton*
Unitary Commercial Heat Pump (HP), Air-cooled (Cooling Mode)	Less than 64 tons	Split system and single package	\$50/ton	N/A
	5 tons or less	Split system and single package	N/A	\$70/ton
Unitary Commercial AC, Water-cooled	ANY SIZE	Split system and single package	\$40/ton*	N/A
Unitary Commercial HP, Water-cooled (Cooling Mode)	11 tons or less	86 degree F entering water	\$100/ton*	N/A
Variable Refrigerant Flow (VRF) AC, Air-cooled (Cooling Mode)	ANY SIZE	Multisplit AC	\$35/ton*	N/A
	5 tons or less	Multisplit AC	N/A	\$55/ton*
VRF HP, Air-cooled (Cooling Mode)	ANY SIZE	Multisplit AC	\$50/ton	N/A
	5 tons or less	Multisplit AC	N/A	\$85/ton
VRF HP, Water-cooled (Cooling Mode)	11 tons or less	Multisplit, 86 degree F entering water	\$100/ton*	N/A

*Available in Idaho only.

Notes:

1. Efficiency is based on Air-Conditioning, Heating, and Refrigeration Institute (AHRI) and International Organization for Standardization (ISO) standards.
2. Based on Consortium of Energy Efficiency (CEE) 2019 Standards.