

A7 & R3 Evaporative Pre-Cooler on an Air-cooled Condenser Requirements*

An incentive of \$30 per ton is available for the installation of an evaporative pre-cooler used to pre-cool ambient air before it reaches the air-cooled condenser for HVAC systems or refrigeration systems.

- Self-contained evaporative condensing coils are not eligible as part of this measure.
- System must be purchased and installed by a qualified contractor.
- Eligible equipment must have a minimum performance efficiency of 75%.
- System must have enthalpy controls to control pre-cooler operation.
- Water supply must have chemical or mechanical water treatment. Magnetic water treatment does not qualify for this measure.

*Available in Idaho only.